

Disabled Refuge Advance Green



The Omnicare system offers a choice of outstation units which can be wired on the same loop from the control panel.

The BVOCA2G Advance green disabled refuge remote unit is one of the options available on this versatile system.

Omnicare

BENEFITS & FEATURES:

- Provides two-way, hands free, speech steered communication.
- Self-powered from ring circuit, no local power source is required. Automatic battery backup is provided by the control panel in the event of a mains power failure.
- Green finish (also available in stainless steel BVOCA2S).
- Addressable unit.
- Induction loop, Braille, tactile and luminescent text. The front panel is also framed by a luminescent border.
- Volt free contact, which is active when 'occupied', to operate over-door lamps, silence speaker/sounder, etc.
- Large, easy to use, call button with an integral illuminated ring, which ensures visibility at all times.
- Calls can be reset either by an extended press of the button on the remote unit or at the master control panel.
- All outstations are in a loop circuit from control panel(s).
- A link to the fire detection system prevents hoax disabled refuge calls. This feature can be completely, or partly, overridden.
- Surface mounting unit (can be flush mounted using a bezel).

PRODUCT CODES:

- BVOCA2G - Advance outstation in green.
- BVOCA2GBZ - Optional bezel to flush mount.



Specifications:

	Advanced Disabled Refuge (DRS)
Product code	BVOCA2G
Power supply	12-40V DC self powered from ring circuit
Power consumption	30mA @ 35V typical
Weight	3.5 kg
Humidity range	95% non-condensing
Temperature range	-10°C to +40°C
Indicators	System healthy, system activated, in use
Finish	Green with Braille and tactile/luminescent text
Dimensions mm W x H x D	180 x 440 x 64
Bezel dimensions W x H	230 x 490
Bezel cutout mm W x H	190 x 450
Knockouts/cable entry points	20 mm & 25 mm
Mounting position	Refuge remotes should be placed at a height of 900 mm to 1.2 m

SYSTEM REQUIREMENTS:

- Fire rated enhanced four core, colour coded cable with a screen must be used for firefighting systems.
- Standard fire resisting cables could be considered for:
 - EVC systems for use in disabled refuges but not for firefighting in (a) sprinklered buildings; (b) unsprinklered buildings less than 30m in height, provided that evacuation takes place in three or fewer phases.
 - Underground sections of cabling at sports and similar venues.
- Up to 200m cable run between remote units and master control panel as standard.
- A repeater unit (BVOCRIF) must be used if distance between remotes exceeds 200m.
- Disabled refuge, advance disabled refuge, fire telephone, emergency/steward telephone, combined DRS/fire telephone and toilet alarm units can be placed on the same loop.
- A ring circuit configuration must be used to wire the remote units. Typically 20-30 remotes per loop.
- Repeater units (BVOCRIF) are used to connect the toilet alarms to the system.



BALDWIN BOXALL
LEADING THE WAY TO SAFETY

Baldwin Boxall Communications Ltd
Wealden Industrial Estate, Farningham Road,
Crowborough, East Sussex, TN6 2JR, United Kingdom

T: +44 (0) 1892 664422 F: +44 (0) 1892 663146
E: mail@baldwinboxall.co.uk
W: www.baldwinboxall.co.uk